

Rotary actuator fail-safe for adjusting dampers in technical building installations

- Air damper size up to approx. 4 m<sup>2</sup>
- Torque motor 20 Nm
- Nominal voltage AC 24...240 V / DC 24...125 V
- Control Open/close
- with 2 integrated auxiliary switches



**Technical data sheet** 

## Technical data

Electrical data	Nominal voltage	AC 24240 V / DC 24125 V				
	Nominal voltage frequency	50/60 Hz				
	Nominal voltage range	AC 19.2264 V / DC 21.6137.5 V				
	Power consumption in operation	7 W				
	Power consumption in rest position	3.5 W				
	Power consumption for wire sizing	18 VA				
	Auxiliary switch	2 x SPDT, 1 x 10% / 1 x 11100%				
	Switching capacity auxiliary switch	1 mA3 A (0.5 A inductive), DC 5 VAC 250 V				
	Connection supply / control	Cable 1 m, 2 x 0.75 mm <sup>2</sup>				
	Connection auxiliary switch	Cable 1 m, 6 x 0.75 mm <sup>2</sup>				
	Parallel operation	Yes (note the performance data)				
Functional data	Torque motor	20 Nm				
	Torque fail-safe	20 Nm				
	Direction of motion motor	selectable by mounting L/R				
	Direction of motion fail-safe	selectable by mounting L/R				
	Manual override	by means of hand crank and locking switch				
	Angle of rotation	Max. 95°				
	Angle of rotation note	can be limited by adjustable mechanical end stop				
	Running time motor	75 s / 90°				
	Running time fail-safe	<20 s @ -2050°C / <60 s @ -30°C				
	Sound power level, motor	45 dB(A)				
	Mechanical interface	Universal shaft clamp 1025.4 mm				
	Position indication	Mechanical				
	Service life	Min. 60'000 fail-safe positions				
Safety data	Protection class IEC/EN	II, reinforced insulation				
	Protection class UL	II, reinforced insulation				
	Protection class auxiliary switch IEC/EN	II, reinforced insulation				
	Degree of protection IEC/EN	IP54				
	Degree of protection NEMA/UL	NEMA 2				
	Enclosure	UL Enclosure Type 2				
	EMC	CE according to 2014/30/EU				
	Low voltage directive	CE according to 2014/35/EU				
	Certification IEC/EN	IEC/EN 60730-1 and IEC/EN 60730-2-14				
	UL Approval	cULus according to UL60730-1A, UL60730-2-14 and CAN/CSA E60730-1				
		The UL marking on the actuator depends on the production site, the device is UL-compliant in any case				
	Type of action	Type 1.AA.B				
		••				

SFA-S2



## Technical data sheet

Rated impulse voltage supply / control	4 kV					
Rated impulse voltage auxiliary switch	2.5 kV					
Pollution degree	3					
Ambient humidity	Max. 95% RH, non-condensing					
Ambient temperature	-3050°C [-22122°F]					
Storage temperature	-4080°C [-40176°F]					
Servicing	maintenance-free					
Weight	2.3 kg					
	Rated impulse voltage supply / control Rated impulse voltage auxiliary switch Pollution degree Ambient humidity Ambient temperature Storage temperature Servicing	Rated impulse voltage supply / control4 kVRated impulse voltage auxiliary switch2.5 kVPollution degree3Ambient humidityMax. 95% RH, non-condensingAmbient temperature-3050°C [-22122°F]Storage temperature-4080°C [-40176°F]Servicingmaintenance-free				

# Safety notes

Ĺ	<ul> <li>This device has been designed for use in stationary heating, ventilation and air-conditioning systems and must not be used outside the specified field of application, especially in aircraft or in any other airborne means of transport.</li> <li>Outdoor application: only possible in case that no (sea) water, snow, ice, insolation or aggressive gases interfere directly with the device and that it is ensured that the ambient conditions remain within the thresholds according to the data sheet at any time.</li> <li>Caution: Power supply voltage!</li> <li>Only authorised specialists may carry out installation. All applicable legal or institutional installation regulations must be complied during installation.</li> <li>The device may only be opened at the manufacturer's site. It does not contain any parts that can be replaced or repaired by the user.</li> <li>Cables must not be removed from the device.</li> <li>To calculate the torque required, the specifications supplied by the damper manufacturers concerning the cross-section, the design, the installation situation and the ventilation conditions must be observed.</li> <li>The two switches integrated in the actuator are to be operated either on power supply voltage or at safety extra-low voltage. The combination power supply voltage/safety extra-low voltage is not permitted.</li> <li>The device contains electrical and electronic components and must not be disposed of as household refuse. All locally valid regulations and requirements must be observed.</li> </ul>
Product features	The actuator is equipped with a universal power supply module that can utilise supply voltages
Mode of operation	of AC 24240 V and DC 24125V.
	The actuator moves the damper to the operating position at the same time as tensioning the return spring. The damper is turned back to the fail-safe position by spring force when the supply voltage is interrupted.
Simple direct mounting	Simple direct mounting on the damper shaft with a universal shaft clamp, supplied with an anti- rotation device to prevent the actuator from rotating.
Manual override	By using the hand crank the damper can be actuated manually and engaged with the locking switch at any position. Unlocking is carried out manually or automatically by applying the operating voltage.
Adjustable angle of rotation	Adjustable angle of rotation with mechanical end stops.
High functional reliability	The actuator is overload protected, requires no limit switches and automatically stops when the end stop is reached.
Flexible signalling	The actuator has one auxiliary switch with a fixed setting and one adjustable auxiliary switch.

Accessories

Electrical accessories	Description	Туре
	Auxiliary switch 2 x SPDT	S2A-F
	Feedback potentiometer 200 Ω	P200A-F
	Feedback potentiometer 1 kΩ	P1000A-F

They permit a 10% or 11...100% angle of rotation to be signaled.

SFA-S2



**Technical data sheet** 

C	EΛ	c2
ు	ГА	-32

Mechanical accessories	Description	Туре
	Shaft extension 240 mm Ø20 mm for damper shaft Ø 822.7 mm	AV8-25
	End stop indicator	IND-AFB
	Shaft clamp reversible, for central mounting, for damper shafts Ø12.7 / 19.0 / 25.4 mm	К7-2
	Ball joint suitable for damper crank arm KH8 / KH10, Multipack 10 pcs.	KG10A
	Ball joint suitable for damper crank arm KH8, Multipack 10 pcs.	KG8
	Damper crank arm Slot width 8.2 mm, clamping range Ø1018 mm	KH8
	Actuator arm, for 3/4" shafts, clamping range Ø1022 mm, Slot width 8.2 mm	KH-AFB
	Form fit insert 10x10 mm, Multipack 20 pcs.	ZF10-NSA-F
	Form fit insert 12x12 mm, Multipack 20 pcs.	ZF12-NSA-F
	Form fit insert 15x15 mm, Multipack 20 pcs.	ZF15-NSA-F
	Form fit insert 16x16 mm, Multipack 20 pcs.	ZF16-NSA-F
	Mounting kit for linkage operation for flat and side installation	ZG-AFB
	Base plate extension	Z-SF
	Anti-rotation mechanism 230 mm, Multipack 20 pcs.	Z-ARS230L
	Hand crank 63 mm	ZKN2-B

## **Electrical installation**



### Caution: Power supply voltage!

Parallel connection of other actuators possible. Observe the performance data.

### Wire colours:

- 1 = blue
- 2 = brown
- S1 = violet
- S2 = red
- S3 = white
- S4 = orange
- S5 = pink
- S6 = grey

### Wiring diagrams


AC 24...240 V / DC 24...125 V, open/ Auxiliary switch close



		80 V 24 V				$\checkmark$
		80 V 4 V		24 230		
	S1 S	32 S	53 5	4 S	5 5	þ
10%						11100%



## Operating controls and indicators



### Auxiliary switch settings

**Note:** Perform settings on the actuator only in deenergised state.

For the auxiliary switch position settings, carry out points 1 to 7 successively.

# Manual override

Turn the hand crank until the desired switching position is set.

## 2 Shaft clamp

Edge line A displays the desired switching position of the actuator on the scale.

**3** Fasten the locking device

Turn the locking switch to the "Locked padlock" symbol.

## 4 Auxiliary switch

Turn rotary knob until the notch points to the arrow symbol.

## Unlock the locking device

Turn the locking switch to the "Unlocked padlock" symbol or unlock with the hand crank.

### 6 Cable

5


Connect continuity tester to S4 + S5 or to S4 + S6.

## Manual override

Turn the hand crank until the desired switching position is set and check whether the continuity tester shows the switching point.

### Dimensions

### Spindle length



#### **Clamping range**

		1	$\mathbf{A}$
1022	10		1425.4
<u>I</u>		<b>□</b> I	
1925.4		4 1218	

